

F8/AS1 Maintenance Checking

Recommended Maintenance Checking Procedure for Ecoglo S20 signs:

Monthly Maintenance Check *(to be carried out by the Owner or their appointed agent)*

COMPLETED 

- All signs are still configured as at installation and there is no material damage to any of the signs.
- All signs are clean from general dust build up and any other specific obscuring deposits.
- All signs are clearly visible and have not been covered up.
- All lights within 4m of internal S20 signs have been checked that the positions have not altered from design.
- All lights within 4m of internal S20 signs are in working order and clean.
- All automated lighting control systems are operational as per design.

Annual Inspection *(to be carried out by an IQP)* COMPLETED

- All signs are still configured as at installation and there is no material damage to any of the signs.
- All signs are clean from general dust build up and any other specific obscuring deposits.
- All signs are clearly visible and have not been covered up.
- All lights within 4m of internal S20 signs have been checked that the positions have not altered from design.
- All lights within 4m of internal S20 signs are in working order and clean.
- All automated lighting control systems are operational as per design.



VISIBLY BETTER

Ecoglo International Limited

PO Box 7698, Sydenham 8240, 77 Kingsley Street, Sydenham 8023
Christchurch New Zealand

Phone: 03 348 3781 • Fax: 03 343 6821 • Email: info@ecoglo.com • www.ecoglo.co.nz